COMMUNITY DEVELOPMENT
PERMIT CENTER

AIR-GAP/AIR-BREAK (P13)

CALIFORNIA
CITY OF BELMONT

2013 CPC 801.1 TO 801.6

Physical Separation

Trap, if over 5 feet
(1524 mm) in length

Airbreak

Note: Typical airgap of not less than 1" (25.4 mm) as applied
to the waste of a vegetable soaking or washing sink

Note: Potable water shall be discharged to
the drainage system by means of an
approved airgap of two pipe diameters of the
supply inlet, and not less than 1" (25.4 mm).

Flood Level
Rim of Bathtub

Airgap as Applied to Water Supply

Airgap

Rim

Flood Level

Airgap as Applied to Water Supply